


Growth Facilities – Growth chambers and environmental rooms alarm response chart



Response

The Shift Engineer, Vera Velasco, and users are recipients of alarms for several Growth Facilities growth chambers and environmental rooms. For most chambers, Shift engineer checks units upon receiving ^Ddry contact alarms or those related to ^Ttemperature, ^Hhumidity, and/or ^Ppower. *Shift engineers are only expected to check Conviron rooms in DV2016 after reoccurring alarms. The Shift engineer contacts Vera either through email (vera.velasco@utoronto.ca or mobile 905-906-7609) whenever he deems necessary. Vera investigates alarms and reaches out to FMP or contractors when further investigation or repair is required. Vera informs users on a need-to-know basis.

